

B.E Power Engineering 3rd Year 2nd Semester Examination 2025

Subject: Energy Conservation & Sustainability, Time: 3 Hrs.

Full Marks: 100

Answer the questions as per given instructions		Marks
[1]	Answer <i>any five</i> from this question [CO1]	[5×2=10]
(a)	Define energy conservation.	
(b)	What do you mean by Carbon credit?	
(c)	Briefly state the objectives of CEMS (Continuous Emission Monitoring System).	
(d)	Why do we need energy audit?	
(e)	State briefly the global objectives of ISO 14000 Environmental Management Standard certification.	
(f)	Briefly state objectives of sustainability.	
(g)	Briefly state the difference between standard & energy efficient transformer.	
(h)	What is Latent heat thermal storage?	
(i)	Define Macroclimates of a region.	
(j)	Classify radioactive waste materials.	
[2]	Answer <i>any two</i> from this question [CO2]	[10×2=20]
(a)	Classify thermal storage methods & briefly explain any one type with a neat figure.	[2+6+2]
(b)	Briefly explain waste heat recovery scheme in boiler with a neat sketch.	[4+6]
(c)	What is boiler blow down? Briefly explain different types of blow down process.	[5+3+2]
[3]	Answer <i>any two</i> from this question [CO3]	[10×2=20]
(a)	State the steps of energy audit. Briefly explain energy efficient lighting control?	[5+5]
(b)	Briefly explain: Soft starter, maximum demand controller, Electronics ballast, Automatic power factor controller.	[2.5×2=10]
(c)	Briefly state the benefits of green building. Briefly state the type of equipments those are used in Green Building with a neat schematic diagram.	[4+6]
[4]	Answer <i>any two</i> from this question [CO4]	[10×2=20]
a)	Briefly explain different types of radioactive waste disposal schemes.	[10]
b)	Why do we need boiler assessment? Classify boiler efficiency evaluation method & briefly explain any one type.	[2+2+6]
(c)	What are the challenges of Coastal zone & it's ecosystem? State the objectives of Coastal zone management.	[5+5]
(d)	What are different types of macroclimatic regions? How does macroclimate effects on stationary & mobile source of pollution?	[3+7]
[5]	Answer <i>all</i> from this question [CO5]	[15×2=30]
(a)	A college has three departments (Arts, Commerce & Science.) & their details of electrical appliances & respective loading durations are shown in Table 1&2 . Energy cost is Rs.9/unit. Working is on the basis of 5 days in week. Draw Sankey diagram along with calculate 3 rd year total costing for existing setup. Finally perform energy audit with calculation of saving in rupees per Annum with payback period calculation when replacing energy efficient devices. Also calculate Star rating of building (from EPI calculation). Use data from Table:1 (Loading topology department wise); Table:2 (Details of normal & energy efficient devices) & those are shown in next page.	[15]
(b)	Calculate the Green Building Index (GBI) of a specified building using the data provided in Table: 3 & from that value conclude on the grading of the building. Assume: Gross floor area=253595m ² , service life=60Years Use following Equations: 1. $GBI = (Building\ Hospitality\ Index, Q) \times (Carbon\ Economic\ Index, E) / (Carbon\ Emission\ Index, C)$ 2. $C = \alpha \times (EC_E / EC_R) + \beta \times (OC_E / OC_R)$, where α, β are Weights of area=0.125, EC_E & EC_R =Embodied carbon emission in evaluated building & reference building in construction phase, OC_E & OC_R =Operational carbon emission in evaluated & reference building in operational & maintenance phase. 3. $Q = \sum_{i=1}^5 \left(\frac{Si \times Wi}{DMI} \right) \times \frac{1}{100}$, where Si= Score obtained in evaluated building in specific area i, DMI & Wi are allotted scores & weights for accessing carbon emission from that specific area. 4. $CE = \frac{\Delta RB}{\Delta IC} \times 100 = \left(\frac{OER - OEE + CB}{ICE - ICR} \right) \times 100$, where $\Delta RB, \Delta IC$ are carbon emission reduction benefit & increased construction cost, OER & OEE are annual operational cost for reference building & evaluated building, ICE & ICR are initial construction cost of evaluated building & reference building, CB is carbon emission trading profit, CE is carbon economic efficiency,	[15]

(E=1 if CE<4%); (E=0.05×CE+0.8 if 4%≤CE<8%); (E=1.2 if 8%≤CE)

Table:1 Loading topology department wise (Ref. Q.5.a)

Department	Illumination Level (lumen/m ²)	Volume= Area ×height (m ²)×m	Tube Light (36W) [No./hrs loading]	Cooling requirement (Watt/m ³)	Fan (Convention al) (60W) [No./hrs loading]	Computer (150W) [No./hrs loading]	Pump (0.5h.p) [No./hrs loading]	Air condition 1.5 Ton 3 star 1926W [No./hrs loading]
Arts	200	300×3	35/8	24	908	45/8	2/1	10/8
Commerce	200	200×3	20/8	24	70/8	35/8	2/1	8/8
Science	200	300×3	25/8	24	80/8	40/8	2/1	10/8

Table:2 Details of normal & energy efficient devices (Ref. Q.5.a)

Device	Investment Cost/fitting (Rs.)	Replacement cost/fitting (Rs.)	Illumination (Lumen/m ²)	Power rating (Watt)	Life (hr.)	Cooling Capacity (Watt)	Co- efficient of Utilization	Maintenan ce Factor
Tube light	250	50	2100	36	4000	-----	0.6	1
LED	550	Nil	1800	18	50000	-----	0.6	1
Fan (Conventionally controlled)	450	75	-----	60	80000	-----	0.6	1
Fan (Automatic control)(reduce 3hrs operating time than conventional)	650	75	-----	60	70000	-----	0.6	1
A.C (3 star)	24000	1000	-----	1926	70000	4200	0.6	1
A.C(5 star)	34000	1000	-----	1677	70000	4200	0.6	1

Assume:

$$1. N = (E \times A) / (O \times CU \times MF) \quad \& \quad M = (C \times V) / (CC \times CU \times MF)$$

Where, N & M are No. of Light fitting & Split A.C are needed respectively

E & C are required illumination level in Lux (lumen/m²) & required cooling level in watt/m³ respectivelyA & V are effective area to be illuminated in m² or effective volume to be cooled in m³ respectively

O & CC are luminous flux produces per lamp in lumen & cooling capacity per A.C in watt respectively

CU & MF are Coefficient of utilization & maintenance factor respectively

$$2. \text{Energy Performance Index (EPI)} = \text{Energy consumption/area of building/year (in kWhr/m}^2\text{/year)}$$

Where EPI= 80-70 building rating: 1star; 70-60: 2 star; 60-50: 3 star, 50-40: 4 star; below 40: 5 star

$$3. 1^{\text{st}} \text{ yr annual costing} = \text{investment charge} + 1^{\text{st}} \text{ yr energy charge; } 2^{\text{nd}} \text{ yr total costing} = \text{previous year costing} + 2^{\text{nd}} \text{ yr energy charge; } 3^{\text{rd}} \text{ yr total costing} = \text{previous years' total costing} + 3^{\text{rd}} \text{ yr energy charge} + \text{replacement of fitting charge}$$

Table: 3 Details of Green building parameters (Ref. Q.5.b)

GBI Range	Grade	Carbon Emission Index parameters	Building hospitality index parameters	Wi	DMi	Si	Carbon Economic Index Parameters (Cost/unit area in USD/m ²)		
		Embodied & operational Carbon Emissions/unit					Parameters	Evaluated Building	Reference Building

Ex/PE/PC/B/T/325/2025

		area (Kg/m ²)								
GBI≥4	Green 1st	EC _E =440.5	Ecology	20	30	21.5	Initial construction cost	ICE=350.2	ICR=240.4	
3≤GBI<4	Green 2nd	EC _R =660.5	Health	22	40	30.0	Annual operational cost	OEE=5.2	OER=11.1	
2.5≤GBI<3	Green 3 rd	OC _E =1150	Function	30	30	25.0	Annual carbon emission trading profit	CB=0.6	CB=0.0	
2≤GBI<2.5	Green 4th	OC _R =2550.6	Energy Efficiency	25	35	25.0				
GBI<2	Out of Grade		Resource Efficiency	20	25	28.05				